



Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Batch No:	15-42639	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	520960	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	12-Oct-2015
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	12-Oct-2015
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	15-Oct-2015
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	Bangholme Training Tanks		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Alg. ScCnt	MB006	Scoresby	Colilert (2000)	MM514	Scoresby
Ps aeruginosa	MM528	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Manager Botany		Deputy Team Leader
	Analyst		Microbiology

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.
VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
Calculated results are based on raw data.

Page: Page 2 of 2
 Batch No: 15-42639
 Report Number: 520960
 Client: Country Fire Authority
 ALS Program Ref: CFA
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4484487	CFAB01	Flammable Liquid Tank	WATER	12/10/15 14:00
4484488	CFAB02	South Megalitre Tank	WATER	12/10/15 14:00
4484489	CFAB03	North Megalitre Tank	WATER	12/10/15 14:00

Analysis - Analyte	Sample No. Site Code Units	4484487 CFAB01	4484488 CFAB02	4484489 CFAB03
Alg. ScCnt - Algal analyses		NR IND	NR IND	NR IND
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0

IND Reported independently on separate report