

Victorian Emergency Management Training Centre - Bangholme  
Thompsons Road Bangholme VIC 3175  
Ref: Water Quality 2015-Bangholme Batch-15-11759



12 March 2015

Program Manager  
Office of the CEO  
Country Fire Authority  
8 Lakeside Drive  
Burwood East Vic 3151

TO WHOM IT MAY CONCERN

**Water Monitoring Results: Bangholme Campus – Batch 15-11759**

I refer to the attached water test results received from the ALS Group, who undertook the tests in accordance with the water monitoring program set out in CFA's Water Management Plans. ALS Group is an independent laboratory certified by the National Association of Testing Authorities (NATA).

The attached test results indicate that the water sample collected on 4 March 2015 exceeded the criterion in the North Megalitre Tank. This tank will not be used for training until corrective action is taken and a successful test result is achieved.

Yours sincerely

Business Manager



**Business Manager**  
VEMTC - Bangholme – Thompsons Road Bangholme VIC 3175





Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Batch No: 15-11759 Page Page 1 of 2
Final Report 485358
Client: CFA Laboratory Scoresby Laboratory
Address: PO Box 717 PATTERSON LAKES VIC 3197 Address 22 Dalmore Drive, Scoresby, VIC 3179
Phone 03 8756 8000
Fax 03 9763 1862
Contact: Client Manager
PO No: Not Available Date Sampled: 04-Mar-2015
Sampler Name: Date Samples Received: 04-Mar-2015
ALS Program Ref: CFA Date Issued: 10-Mar-2015
Program Description: Miscellaneous Analyses
Client Ref: Tank Analysis

The sample(s) referred to in this report were analysed by the following method(s):
# - NATA accreditation does not cover the performance of this service.

Table with 6 columns: Analysis, Method, Laboratory, Analysis, Method, Laboratory. Row 1: Colilert (2000), MM514, Scoresby, Ps aeruginosa, MM528, Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Table with 4 columns: Name, Title, Name, Title. Row 1: Analyst, Deputy Team Leader Microbiology, Team Leader Microbiology

Samples not collected by ALS and are tested as received.
Soil results expressed in mg/kg dry weight unless specified otherwise.
Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.
VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
Calculated results are based on raw data.

Page: Page 2 of 2  
 Batch No: 15-11759  
 Report Number: 485358  
 Client: CFA  
 ALS Program Ref: CFA  
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4247881		Flammable Liquid Tank	WATER	04/03/15
4247882		South Megalitre Tank	WATER	04/03/15
4247883		North Megalitre Tank	WATER	04/03/15

Analysis - Analyte	Sample No.	4247881	4247882	4247883
	Site Code Units			
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	1	0	18
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	2

