

CENTRAL HIGHLANDS WATER - LABORATORY SERVICES

7 Learmonth Rd. Wendouree, PO Box 152, Ballarat 3353 ABN: 75 224 340 348

Chemistry: 03 53203195 Microbiology: 03 53 203193 Email: laboratory@chw.net.au

TEST REPORT

Laboratory Report No: 14/3491

Client: CFA Training College - Fiskeville
Ballan - Geelong Road
FISKEVILLE VIC 3342

Attention:

Date Received: 24/07/14

Job Description: CFA Training Centre Fiskville

LAB. No.	SAMPLE	SAMPLED
14/3491-1	Red Pipe - PG Tank	24/07/2014
14/3491-2	Beige Pipe - BU Tank	24/07/2014

Test Description	Method	Units	14/3491-1	14/3491-2
BOD ₅	CHW - BOD	mg/L	[NT]	[NT]
E. coli - Colilert	CHWM.08	MPN/100mL	0	0
Electrical Conductivity @ 25°C	CHW - EC	µS/cm	540	530
Oil & Grease at ALS		mg/L	10	<5
pH	CHW - pH	Units	8.0	8.2
Ps. aeruginosa	CHWM.07	cfu/100mL	0	0
Phosphorus - Total (Low)	CHW - Tot P	mg/L	[NT]	[NT]
Suspended Solids	CHW - SS	mg/L	1	<1
Total Dissolved Solids	CHW - TDS	mg/L	290	260
Total Nitrogen (as N)	CHW - Tot N	mg/L	[NT]	[NT]
Total Oxidised Nitrogen (as N)	CHW - Ox.N	mg/L	[NT]	[NT]

Analytical methods for chemical analyses in accordance with Central Highlands Water Laboratory Chemistry Methods (2013).
Analytical methods for microbiological analyses in accordance with Central Highlands Water Microbiology Methods Manual (2013).
Volatile Acid analysis not covered by NATA Accreditation.

Comments

Samples as received. NT - Test not performed.
Bacteriological analysis performed on day of receipt.
O&G analysis performed at ALS, Accreditation No. 992.
Refer ALS Report No. 448518.

Signed

Report Date: 8 August 2014

Name

Chemistry

Microbiology

Page 1 of 1



Accredited for compliance
with ISO/IEC 17025

Accreditation No: 1935

This report is not to be reproduced except in full.