

CENTRAL HIGHLANDS WATER - LABORATORY SERVICES

7 Learmonth Rd. Wendouree, PO Box 152, Ballarat 3353 ABN: 75 224 340 348
 Chemistry: 03 53203195 Microbiology: 03 53 203193 Email: laboratory@chw.net.au

TEST REPORT

Laboratory Report No: 14/1976

Client: CFA Training College - Fiskeville
 Ballan - Geelong Road
 FISKEVILLE VIC 3342

Attention:

Date Received: 24/04/14

Job Description: CFA Training Centre Fiskville



LAB. No.	SAMPLE	SAMPLED
14/1976-1	Red Pipe - PG Tank	24/04/2014
14/1976-2	Beige Pipe - BU Tank	24/04/2014

Test Description	Method	Units	14/1976-1	14/1976-2
BOD ₅	CHW - BOD	mg/L	<5	<5
E. coli - Colilert	CHWM.08	MPN/100mL	0	0
Electrical Conductivity @ 25°C	CHW - EC	µS/cm	540	530
Oil & Grease at ALS		mg/L	<5	<5
pH	CHW - pH	Units	8.4	8.1
Ps. aeruginosa	CHWM.07	cfu/100mL	0	0
Phosphorus - Total (Low)	CHW - TotP	mg/L	0.010	0.010
Suspended Solids	CHW - SS	mg/L	1	<1
Total Kjeldahl Nitrogen (as N)	CHW - TKN2	mg/L	0.5	0.3
Total Oxidised Nitrogen (as N)	CHW - Ox.N	mg/L	0.76	0.82

Analytical methods for chemical analyses in accordance with Central Highlands Water Laboratory Chemistry Methods (2013).
 Analytical methods for microbiological analyses in accordance with Central Highlands Water Microbiology Methods Manual (2013).
 Volatile Acid analysis not covered by NATA Accreditation.

Comments

Samples as received.
 Bacteriological analysis performed on day of receipt.
 O&G analysis performed at ALS, Accreditation No. 992.
 Refer ALS Report No. 432682.

Signed



Report Date: 8 May 2014

Name

Chemistry

Microbiology

Page 1 of 1



Accredited for compliance with ISO/IEC 17025

Accreditation No: 1935

This report is not to be reproduced except in full.