



Tuesday, 2 February 2016
Programme Manager
Office of the CEO
Country Fire Authority
8 Lakeside Drive
Burwood East Vic 3151

To whom it may concern,

Water Monitoring Results: VEMTC Huntly Campus – Batch 16-04394

I refer to the attached water test results received from the ALS Group, who undertook the tests in accordance with the water monitoring program set out in CFA's Water Management Plans. ALS Group is an independent laboratory certified by the National Association of Testing Authorities (NATA).

The attached test results indicate that the water sample collected on 18 January 2016 exceeded the criterion in the hydrant. This hydrant will not be used for training until corrective action is taken and a successful test result is achieved.

Yours sincerely

A handwritten signature in black ink, appearing to read 'John Bell', is written over a printed name and title.

John Bell
VEMTC Lead



John Bell VEMTC Lead
Headquarters – Learning & Volunteerism
16 Lakeside Drive Burwood East Vic 3151
T: 03 9262 8065 E: j.bell@cfa.vic.gov.au



CERTIFICATE OF ANALYSIS

Batch No:	16-04394	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	538840	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	CFA Training Ground - Huntly Campus	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>		<i>Phone</i>	03 5441 0700
<i>Address:</i>	PO Box 383 HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
		<i>Contact:</i>	Process Co-ordinator
 <i>PO No:</i>	 LP 349626	 <i>Date Sampled:</i>	 18-Jan-2016
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	18-Jan-2016
<i>ALS Program Ref:</i>	CFABGO	<i>Date Issued:</i>	27-Jan-2016
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	Huntly		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Team Leader Microbiology		Process Co-ordinator

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4624614		Tank No 8	WATER	18/01/16 09:46
4624615		Tank No 9	WATER	18/01/16 09:37
4624616		Tank No 10	WATER	18/01/16 09:30
4624617		Hydrant	WATER	18/01/16 09:41

Analysis - Analyte	Sample No. Site Code Units	4624614	4624615	4624616	4624617
		BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0	110

A blank space indicates no test performed.