

**CERTIFICATE OF ANALYSIS**

<b>Batch No:</b>	<b>16-07181</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>540915</b>	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	<b>CFA Training Ground - Huntly Campus</b>	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>		<i>Phone</i>	03 5441 0700
<i>Address:</i>	PO Box 383 HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
		<i>Contact:</i>	Bendigo Laboratory Manager
<i>PO No:</i>	<b>LP 349628</b>	<i>Date Sampled:</i>	<b>04-Feb-2016</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>04-Feb-2016</b>
<i>ALS Program Ref:</i>	<b>CFABGO</b>	<i>Date Issued:</i>	<b>08-Feb-2016</b>
<i>Program Description:</i>	<b>Miscellaneous Analyses</b>		
<i>Client Ref:</i>	<b>Huntly Retest</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Ps aeruginosa	MM528	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

**Signatories**

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Deputy Team Leader</b>		
	<b>Microbiology</b>		

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Page: Page 2 of 2  
 Batch No: 16-07181  
 Report Number: 540915  
 Client: CFA Training Ground - Huntly Campus  
 ALS Program Ref: CFABGO  
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4644225		Hydrant	WATER	04/02/16

Analysis - Analyte	Sample No. Site Code Units	4644225
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	3

A blank space indicates no test performed.