

CERTIFICATE OF ANALYSIS

Batch No:	16-09756	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	544008	<i>Laboratory</i>	Wangaratta Laboratory
<i>Client:</i>	CFA	<i>Address</i>	48 Faithfull Street, Wangaratta, VIC 3677.
<i>Contact:</i>		<i>Phone</i>	03 5722 2688
<i>Address:</i>	1 Ely Street WANGARATTA VIC 3677	<i>Fax</i>	03 5722 4727
		<i>Contact:</i>	Wangaratta Laboratory Manager

<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	18-Feb-2016
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	18-Feb-2016
<i>ALS Program Ref:</i>	CFAWANG	<i>Date Issued:</i>	24-Feb-2016
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	Misc Analysis		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Wangaratta	Colilert (2000)	MM514	Wangaratta
pH	CM060 B	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	EA025WRG	Wangaratta			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Analyst		Analyst
	Wangaratta Laboratory		
	Manager		



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4663652		Underground Tank	WATER	18/02/16 09:35
4663655		Main Hydrant	WATER	18/02/16 09:25

Analysis - Analyte	Sample No. Site Code Units	4663652	4663655
	pH - pH, units	Units	8.7
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	5	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	81	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	1	0

A blank space indicates no test performed.