



Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Batch No:	13-31051	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	383492	<i>Laboratory</i>	Traralgon Laboratory
<i>Client:</i>	CFA Training College West Sale Campus	<i>Address</i>	4/55 Hazelwood Road, Traralgon, VIC 3844
<i>Contact:</i>	[REDACTED]	<i>Phone</i>	03 5176 4170
<i>Address:</i>	Cnr Cowwarr/Sale Rd & Princess Hwy P.O Box 1212 Sale Vic 3850	<i>Fax</i>	03 5176 4473
		<i>Contact:</i>	
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	15-Jul-2013
<i>Sampler Name:</i>	[REDACTED]	<i>Date Samples Received:</i>	15-Jul-2013
<i>ALS Program Ref:</i>	SUNDRY_TRA	<i>Date Issued:</i>	18-Jul-2013
<i>Program Description:</i>	Sundry Customer Program for Traralgon		
<i>Client Ref:</i>	CFA - Sale		

The sample(s) referred to in this report were analysed by the following method(s):
- NATA accreditation does not cover the performance of this service

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Colilert (2000)	MM514	Traralgon	Enterococci	MM572	Traralgon
Ps aeruginosa	MM528	Traralgon			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
[REDACTED]	Traralgon Laboratory Manager		



Samples tested as received.

Soil results expressed in mg/kg dry weight unless specified otherwise.

Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.

VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Page: Page 2 of 2
 Batch No: 13-31051
 Report Number: 383492
 Client: CFA Training College West Sale Campus
 ALS Program Ref: SUNDRY_TRA
 Program Description: Sundry Customer Program for Traralgon



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
3541030		Mains Water - - Millcock S/E Crn Dam	WATER	15/07/13 08:00

Analysis - Analyte	Sample No. Site Code Units	3541030
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Enterococci - Enterococci	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0