



Page: Page 3 of 3
 Batch No: 15-27003
 Report Number: 503129
 Client: CFA Training Ground - Huntly Campus
 Client Program Ref: Water Analysis

Chemistry

Sample	Sampled Date	Your Ref	Analysis:	BOD5
			Component: Units: Sample Type	BOD mg/L
4363375	15-06-15	Tank No 8	WATER	2
4363376	15-06-15	Tank No 9	WATER	3
4363377	15-06-15	Tank No 10	WATER	3
4363378	15-06-15	Hydrant	WATER	3

Microbiology

Sample	Sampled Date	Your Ref	Analysis:	Coliart (2000)	Ps aeruginosa
			Component: Units: Sample Type	E.coli orgs/100mL	orgs/100mL
4363375	15-06-15	Tank No 8	WATER	0	2
4363376	15-06-15	Tank No 9	WATER	0	0
4363377	15-06-15	Tank No 10	WATER	0	0
4363378	15-06-15	Hydrant	WATER	0	0

Samples collected by ALS according to procedure EN/67.

A blank space indicates no test performed. Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced within 24 hours of sampling unless otherwise stated. VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate. VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate. Calculated results are based on raw data.