



Environmental Division (Water Resources Group)



NATA Accredited Laboratory No. 992  
Accredited for compliance with ISO/IEC 17025  
WORLD RECOGNISED ACCREDITATION



### CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>15-44980</b>	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	<b>521464</b>	<i>Laboratory</i>	Wangaratta Laboratory
<i>Client:</i>	<b>CFA</b>	<i>Address</i>	48 Faithfull Street, Wangaratta, VIC 3677.
<i>Contact:</i>		<i>Phone</i>	03 5722 2688
<i>Address:</i>	1 Ely Street WANGARATTA VIC 3677	<i>Fax</i>	03 5722 4727
		<i>Contact:</i>	Wangaratta Laboratory Manager
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>13-Oct-2015</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>13-Oct-2015</b>
<i>ALS Program Ref:</i>	<b>CFAWANG</b>	<i>Date Issued:</i>	<b>19-Oct-2015</b>
<i>Program Description:</i>	<b>Miscellaneous Analyses</b>		
<i>Client Ref:</i>	<b>Misc Analysis</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Wangaratta	Colilert (2000)	MM514	Wangaratta
pH	VIC-CM060 B	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	EA025WRG	Wangaratta			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

#### Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Microbiologist</b>		<b>Analyst</b>
	<b>Wangaratta Laboratory</b>		
	<b>Manager</b>		



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.  
VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.  
VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.  
Calculated results are based on raw data.

Environmental

[www.alsglobal.com](http://www.alsglobal.com)

RIGHT SOLUTIONS RIGHT PARTNER

Page: Page 2 of 2  
 Batch No: 15-44980  
 Report Number: 521464  
 Client: CFA  
 ALS Program Ref: CFAWANG  
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4506183		Underground Tank	WATER	13/10/15 11:20
4506184		Main Hydrant	WATER	13/10/15 11:15

Analysis - Analyte	Sample No.	4506183	4506184
	Site Code Units		
pH - pH, units	Units	8.3	8.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0