



Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Batch No: 15-21612 Page Laboratory Scoresby Laboratory
Final Report 496308 Address Scoresby Laboratory
Client: CFA Address 22 Dalmore Drive, Scoresby, VIC 3179
Contact: Phone 03 8756 8000
Address: PO Box 717 Fax 03 9763 1862
PATTERSON LAKES VIC 3197 Contact: Client Manager
PO No: Not Available Date Sampled: 08-May-2015
Sampler Name: Date Samples Received: 08-May-2015
ALS Program Ref: CFA Date Issued: 12-May-2015
Program Description: Miscellaneous Analyses
Client Ref: Tank Analysis

The sample(s) referred to in this report were analysed by the following method(s):
- NATA accreditation does not cover the performance of this service

Table with 6 columns: Analysis, Method, Laboratory, Analysis, Method, Laboratory. Row 1: Colilert (2000), MM514, Scoresby, Ps aeruginosa, MM528, Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Table with 4 columns: Name, Title, Name, Title. Row 1: Deputy Team Leader Microbiology, Analyst

Samples not collected by ALS and are tested as received.
Soil results expressed in mg/kg dry weight unless specified otherwise.
Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.
VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
Calculated results are based on raw data.

Page: Page 2 of 2
 Batch No: 15-21612
 Report Number: 496308
 Client: CFA
 ALS Program Ref: CFA
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4323160		Flammable Liquid Tank	WATER	08/05/15
4323161		South Megalitre Tank	WATER	08/05/15
4323162		North Megalitre Tank	WATER	08/05/15

Analysis - Analyte	Sample No.	4323160	4323161	4323162
	Site Code Units			
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0