




Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Table with 4 columns: Field Name, Value, Page, and Laboratory/Contact Info. Includes fields like Batch No, Final Report, Client, Address, PO No, Sampler Name, etc.

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Table with 6 columns: Analysis, Method, Laboratory, Analysis, Method, Laboratory. Lists tests like BOD5, Enterococci, Ps aeruginosa and their respective methods and labs.

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Table with 4 columns: Name, Title, Name, Title. Lists Analyst and Laboratory Technician/Manager.



Samples not collected by ALS and are tested as received. Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.

Page: Page 2 of 2
 Batch No: 15-22530
 Report Number: 497604
 Client: CFA West Sale Training Ground
 ALS Program Ref: CFATRA
 Program Description: Miscellaneous Analyses for CFA West Sale Training Ground



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4328124		Tank Supply to Fire Service	WATER	12/05/15 10:10

Analysis - Analyte	Sample No. Site Code Units	4328124
pH - pH, units	Units	8.2
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Enterococci - Enterococci	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0