

Our Ref: 212163.6Report25.1

5 December 2012

Country Fire Authority
8 Lakeside Drive
East Burwood Vic 3151

Cardno Lane Piper Pty Ltd
Trading as Cardno Lane Piper
ABN 35 120 109 935

Building 2, 154 Highbury Road
Burwood VIC 3125
Australia

Phone: 61 3 9888 0100
Fax: 61 3 9808 3511

www.cardno.com.au
www.lanepiper.com.au

Water Monitoring Results - Bangholme RTG
Date Received: 20 November 2012

I am writing in relation to water quality data received 20 November 2012 from the CFA for the Bangholme RTG. Water used in fire-fighting training was sampled on 14 November 2012 and the report was issued on 19 November 2012.

This test report is derived from the water monitoring program set out in CFA's Water Management Plans with testing by independent laboratories certified by the National Association of Testing Authorities (NATA). Water at Bangholme RTG is sourced for fire-fighting training from the South Megalitre Tank and the North Megalitre Tank¹.

The results have been reviewed by our team of water quality and health specialists and we can report that the results do not indicate any water quality issues that would make the water from the tanks tested unsuitable for use in fire fighting training.

Yours faithfully
Cardno Lane Piper Pty Ltd

Approved:



Senior Environmental Chemist



Senior Principal

Enclosed:

NATA Certified Laboratory Reports:

- ALS Report number: 335565 – sample date 14 November 2012

¹ Water is not used directly in fire-fighting training at this RTG from the following sources; the Concrete Tank and the Flammable Liquids Tank.

Australia • Belgium • Canada • Ecuador • Germany • Indonesia • Italy • Kenya •
New Zealand • Papua New Guinea • Peru • Tanzania • United Arab Emirates •
United Kingdom • United States • Operations in 85 countries



Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Batch No:	12-50480	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	335565	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	CFA	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>	[REDACTED]	<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	[REDACTED]
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	14-Nov-2012
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	14-Nov-2012
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	19-Nov-2012
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	Testing of Water Samples		

The sample(s) referred to in this report were analysed by the following method(s):
- NATA accreditation does not cover the performance of this service

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Title</i>
[REDACTED]	Microbiologist	Analyst

Samples tested as received.

Soil results expressed in mg/kg dry weight unless specified otherwise.

Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.

VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

Page: Page 2 of 2
 Batch No: 12-50480
 Report Number: 335565
 Client: CFA
 ALS Program Ref: CFA
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
3253266		Concrete Tank	WATER	14/11/12
3253267		Flammable Liquid Tank	WATER	14/11/12
3253268		South Megalitre Tank	WATER	14/11/12
3253269		North Megalitre Tank	WATER	14/11/12

Analysis - Analyte	Sample No.	3253266	3253267	3253268	3253269
	Site Code Units				
Coliert (2000) - E.coli MPN Coliert	orgs/100mL	3	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0	0