



Shaping the Future

Our Ref: 212163.6Report23.1

9 November 2012

Country Fire Authority
8 Lakeside Drive
East Burwood Vic 3151



Cardno Lane Piper Pty Ltd
Trading as Cardno Lane Piper
ABN 35 120 109 936

Building 2, 154 Highbury Road
Burwood VIC 3125
Australia

Phone: 61 3 9888 0100
Fax: 61 3 9808 3511

www.cardno.com.au
www.lanepiper.com.au

Water Monitoring Results - Bangholme RTG
Date Received: 7 November 2012



I am writing in relation to water quality data received 7 November 2012 from the CFA for the Bangholme RTG. Water used in fire-fighting training was sampled on 31 October 2012 and the report was issued on 7 November 2012.

This test report is derived from the water monitoring program set out in CFA's Water Management Plans with testing by independent laboratories certified by the National Association of Testing Authorities (NATA).

The results have been reviewed by our team of water quality and health specialists and we can report that the results do not indicate any water quality issues that would make the water from the tanks tested unsuitable for use in fire fighting training.

Yours faithfully
Cardno Lane Piper Pty Ltd



Senior Environmental Chemist

Approved:



Senior Principal

Enclosed:

NATA Certified Laboratory Reports:

- ALS Report number: 333849 – sample date 31 October 2012



Environmental Division (Water Resources Group)

CERTIFICATE OF ANALYSIS

| | | | |
|-----------------------------|--|-------------------------------|--|
| Batch No: | 12-48626 | <i>Page</i> | Page 1 of 2 |
| <i>Final Report</i> | 333849 | <i>Laboratory</i> | Scoresby Laboratory |
| <i>Client:</i> | CFA | <i>Address</i> | Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179 |
| <i>Contact:</i> | [REDACTED] | <i>Phone</i> | 03 8756 8000 |
| <i>Address:</i> | PO Box 717 PATTERSON LAKES VIC 3197 | <i>Fax</i> | 03 9763 1862 |
| | | <i>Contact:</i> | [REDACTED] Client Manager |
| <i>PO No:</i> | Not Available | <i>Date Sampled:</i> | 31-Oct-2012 |
| <i>Sampler Name:</i> | | <i>Date Samples Received:</i> | 31-Oct-2012 |
| <i>ALS Program Ref:</i> | CFA | <i>Date Issued:</i> | 07-Nov-2012 |
| <i>Program Description:</i> | Miscellaneous Analyses | | |
| <i>Client Ref:</i> | Tank Analysis | | |

The sample(s) referred to in this report were analysed by the following method(s):
- NATA accreditation does not cover the performance of this service

| <i>Analysis</i> | <i>Method</i> | <i>Laboratory</i> | <i>Analysis</i> | <i>Method</i> | <i>Laboratory</i> |
|-----------------|---------------|-------------------|-----------------|---------------|-------------------|
| Colliert (2000) | MM514 | Scoresby | Ps aeruginosa | MM528 | Scoresby |

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

| <i>Name</i> | <i>Title</i> | <i>Name</i> | <i>Title</i> |
|-------------|----------------|-------------|--------------|
| [REDACTED] | Microbiologist | [REDACTED] | Analyst |

Samples tested as received.

Soil results expressed in mg/kg dry weight unless specified otherwise.

Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.

VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

Page: Page 2 of 2
 Batch No: 12-48626
 Report Number: 333849
 Client: CFA
 ALS Program Ref: CFA
 Program Description: Miscellaneous Analyses



| Sample No | Site Code | Site Description | Sample Type | Sampled Date/Time |
|-----------|-----------|-----------------------|-------------|-------------------|
| 3237722 | | Concrete Tank | WATER | 31/10/12 |
| 3237723 | | Flammable Liquid Tank | WATER | 31/10/12 |
| 3237724 | | South Megalitre tank | WATER | 31/10/12 |
| 3237725 | | North Megalitre Tank | WATER | 31/10/12 |

| Analysis - Analyte | Sample No. | 3237722 | 3237723 | 3237724 | 3237725 |
|--|--------------------|---------|---------|---------|---------|
| | Site Code Units | | | | |
| Colilert (2000) - E.coli MPN Colilert | orgs/100mL | 0 | 0 | 0 | 0 |
| Ps aeruginosa - Pseudomonas aeruginosa | orgs/100mL | 0 | 0 | 0 | 0 |