

CENTRAL HIGHLANDS WATER - LABORATORY SERVICES

7 Learmonth Rd. Wendouree, PO Box 152, Ballarat 3353 ABN: 75 224 340 348
Chemistry: 03 53203195 Microbiology: 03 53 203193 Email: laboratory@chw.net.au

TEST REPORT

Laboratory Report No: 13/3416

Client: CFA Training College - Fiskeville
Ballan - Geelong Road
FISKEVILLE VIC 3342

Attention: [REDACTED]

Date Received: 18/07/13

Job Description: CFA Training Centre Fiskville

LAB. No.	SAMPLE	SAMPLED
13/3416-1	Red Pipe - PG Tank	18/07/2013
13/3416-2	Beige Pipe - BU Tank	18/07/2013

Test Description	Method	Units	13/3416-1	13/3416-2
BOD ₅	CHW - BOD	mg/L	<5	<5
E. coli - Colilert	CHWM.08	MPN/100mL	0	0
Electrical Conductivity @ 25°C	CHW - EC	µS/cm	490	500
Oil & Grease at ALS		mg/L	<5	<5
pH	CHW - pH	Units	8.4	8.5
Ps. aeruginosa	CHWM.07	cfu/100mL	0	0
Phosphorus - Total (Low)	CHW - TotP	mg/L	0.0050	0.025
Suspended Solids	CHW - SS	mg/L	<1	<1
Total Kjeldahl Nitrogen (as N)	CHW - TKN	mg/L	1.0	0.5
Total Oxidised Nitrogen (as N)	CHW - Ox.N	mg/L	0.41	0.90

Analytical methods for chemical analyses in accordance with Central Highlands Water Laboratory Chemistry Methods (2013).
Analytical methods for microbiological analyses in accordance with Central Highlands Water Microbiology Methods Manual (2013).
Volatile Acid analysis not covered by NATA Accreditation.

Comments

Samples as received.
Bacteriological analysis performed on day of receipt.
O&G analysis performed at ALS, Accreditation No. 992.
Refer ALS Report No. 384377.

Signed [REDACTED]

Report Date: 30 July 2013

Name [REDACTED]

Chemistry

Microbiology

Page 1 of 1



Accredited for compliance
with ISO/IEC 17025

Accreditation No: 1935

This report is not to be reproduced except in full.