

**CERTIFICATE OF ANALYSIS**

<b>Batch No:</b>	<b>15-32137</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>507850</b>	<i>Laboratory</i>	<b>Scoresby Laboratory</b>
<i>Client:</i>	<b>CFA</b>	<i>Address</i>	<b>Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179</b>
<i>Contact:</i>		<i>Phone</i>	<b>03 8756 8000</b>
<i>Address:</i>	<b>PO Box 717 PATTERSON LAKES VIC 3197</b>	<i>Fax</i>	<b>03 9763 1862</b>
		<i>Contact:</i>	<b>Client Manager</b>
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>15-Jul-2015</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>16-Jul-2015</b>
<i>ALS Program Ref:</i>	<b>CFALONG</b>	<i>Date Issued:</i>	<b>23-Jul-2015</b>
<i>Program Description:</i>	<b>Miscellaneous Analysis for CFA Longerenong</b>		
<i>Client Ref:</i>	<b>CFA Longerenong</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Scoresby	Colilert (2000)	MM514	Scoresby
pH	VIC-CM060 B	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	EA025WRG	Scoresby	Turbidity	VIC-CM013	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Analysis conducted outside holding time due to late arrival or delayed extraction/analysis. Based on APHA, VICEPA, AS & NEPM

Late Analysis - Turbidity[4401520]

**Signatories**

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Team Leader Nutrients Analyst</b>		<b>Analyst Deputy Team Leader Microbiology</b>

Page: Page 2 of 2  
 Batch No: 15-32137  
 Report Number: 507850  
 Client: CFA  
 ALS Program Ref: CFALONG  
 Program Description: Miscellaneous Analysis for CFA Longerenong



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4401519		CFAL01A - Primary Supply	WATER	15/07/15 14:30
4401520		CFAL02A - Secondary Supply	WATER	15/07/15 14:30

Analysis - Analyte	Sample No. Site Code Units	4401519	4401520
		pH - pH, units	Units
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	2	2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Turbidity - Turbidity, NTU	NTU	2.1	3.8
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	1	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0