

CERTIFICATE OF ANALYSIS

Batch No:	15-31740	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	507614	<i>Laboratory</i>	Traralgon Laboratory
<i>Client:</i>	CFA West Sale Training Ground	<i>Address</i>	4/55 Hazelwood Road, Traralgon, VIC 3844
<i>Contact:</i>		<i>Phone</i>	03 5176 4170
<i>Address:</i>	PO Box 1212 SALE VIC 3850	<i>Fax</i>	03 5176 4473
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	14-Jul-2015
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	14-Jul-2015
<i>ALS Program Ref:</i>	CFATRA	<i>Date Issued:</i>	21-Jul-2015
<i>Program Description:</i>	Miscellaneous Analyses for CFA West Sale Training Ground		
<i>Client Ref:</i>	Monthly analysis		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Scoresby	Colilert (2000)	MM514	Traralgon
Enterococci	MM572	Traralgon	pH	VIC-CM060 B	Traralgon
Ps aeruginosa	MM528	Traralgon	SS at 104+/- 2°C	EA025WRG	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Team Leader Nutrients		Analyst
	Traralgon Laboratory Manager		

Page: Page 2 of 2
 Batch No: 15-31740
 Report Number: 507614
 Client: CFA West Sale Training Ground
 ALS Program Ref: CFATRA
 Program Description: Miscellaneous Analyses for CFA West Sale Training Ground



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4398674		Tank Supply to Fire Service	WATER	14/07/15 08:50
4398675		Tank Supply Amenities	WATER	14/07/15 09:00

Analysis - Analyte	Sample No.	4398674	4398675
	Site Code Units		
pH - pH, units	Units	7.7	8.1
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterococci - Enterococci	orgs/100mL	<2	<2
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	<2	<2