



CERTIFICATE OF ANALYSIS

Batch No: 21-44351 Final Report

917264

Contact: Address

PO No:

Sampler Name:

Client Ref:

Client:

Page

Page 1 of 2

Laboratory Wangaratta Laboratory Address

48 Faithfull Street, Wangaratta,

VIC 3677.

Phone 03 5722 2688 Fax 03 5722 4727

Contact:

Client Manager

14-Sep-2021

Date Sampled:

Date Samples Received: 13-Sep-2021

Date Issued:

21-Sep-2021

ALS Program Ref: SEVERSACFAWANG

Program Description: CFA VEMTC Program - Wangaratta

Not Available

CFA Wangaratta - WQMP

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service .

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
EC (Field)	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Redox (Field)	# EA075FD	Wangaratta	Temp (Field)	EN67.2	Wangaratta
BOD5	WP030	Wangaratta	Colilert (2000)	MM514	Wangaratta
Enterococci	MM313	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

Signatories

Name Name Title Wangaratta Lab Coordinator Senior Microbiologist

NATA

Accreditation No. 992 ited for compliance with ISO/IEC 17025 - Testing

The report shall not be reproduced. except in full and results relate only to the items tested.

Samples collected by ALS according to procedure EN/67

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.

Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link

Samples are tested within holding time unless otherwise stated.

 Page:
 Page 2 of 2

 Batch No:
 21-44351

 Report Number:
 917264

Client: Senversa Pty Ltd

ALS Program Ref: SEVERSACFAWANG

Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7155055	WA_TA01	Underground Tank	WATER	14/09/21 08:40

Analysis - Analyte	Sample No. Site Code Units	7155055 WA_TA01
Temp (Field) - Temperature (Field)	С	14.6
pH (Field) - pH (Field)	Units	8.3
EC (Field) - Electrical Conductivity (Field)	uS/cm	140
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.5
Field Cl2 - Free Chlorine (Field)	mg/L	1.3
Field Cl2 - Total Chlorine (Field)	mg/L	1.4
Redox (Field) - Redox Potential (Field)	mV	532.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Enterococci - Enterococci	cfu/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

A blank space indicates no test performed.