



CERTIFICATE OF ANALYSIS

Batch No: 21-56304 929710 Final Report

Client: Contact:

Address

PO No:

Page

Page 1 of 2

Laboratory Wangaratta Laboratory

48 Faithfull Street, Address

Wangaratta, VIC 3677.

Phone 03 5722 2688 Fax 03 5722 4727

Contact:

Client Manager

23-Nov-2021 Date Sampled:

Date Samples Received: 23-Nov-2021 30-Nov-2021

Date Issued:

ALS Program Ref: Program Description: Client Ref:

Sampler Name:

SEVERSACFAWANG CFA VEMTC Program - Wangaratta

Not Available

NATA

Accreditation No. 992 ted for compliance with ISO/IEC 17025 - Testing

The report shall not be reproduced,

except in full and results relate only to

the items tested

CFA Wangaratta WQMP

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service .

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
EC (Field)	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Redox (Field)	# EA075FD	Wangaratta	Temp (Field)	EN67.2	Wangaratta
BOD5	WP030	Wangaratta	Colilert (2000)	MM514	Wangaratta
Enterolert	MM517	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

Signatories

Title Name Name Title

Client Manager Wangaratta Lab Coordinator Senior Microbiologist **Bendigo Laboratory Manager**

Samples collected by ALS according to procedure EN/67.

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.

Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link

Samples are tested within holding time unless otherwise stated.

RIGHT SOLUTIONS | RIGHT PARTNER

Page: Page 1 of 2
 Page:
 Page 2 of 2

 Batch No:
 21-56304

 Report Number:
 929710

Client: Senversa Pty Ltd

ALS Program Ref: SEVERSACFAWANG

Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7245506	WA_TA01	Underground Tank	WATER	23/11/21 10:20

Analysis - Analyte	Sample No. Site Code Units	7245506 WA_TA01
Temp (Field) - Temperature (Field)	С	21.9
pH (Field) - pH (Field)	Units	7.9
EC (Field) - Electrical Conductivity (Field)	uS/cm	170
DO (Field) - Dissolved Oxygen (Field)	mg/L	7.9
Field Cl2 - Free Chlorine (Field)	mg/L	1.2
Field Cl2 - Total Chlorine (Field)	mg/L	1.2
Redox (Field) - Redox Potential (Field)	mV	300.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	<2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Enterolert - Enterococci MPN Enterolert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

A blank space indicates no test performed.