

## CERTIFICATE OF ANALYSIS

**Batch No:** 22-43093  
**Replacement Report** 2842  
 This report replaces Report Number: 2828  
**Client:** Senversa Pty Ltd  
**Contact:** [REDACTED]  
**Address:** Ground Floor  
 51 Clarke Street  
 SOUTHBANK  
 VIC  
 3006  
 AUSTRALIA

Page 1 of 2

**Laboratory** Scoresby Laboratory  
**Address** Caribbean Business Park,  
 22 Dalmore Drive,  
 Scoresby,  
 VIC 3179  
**Phone** 03 8756 8000  
**Fax** 03 9763 1862  
**Contact:**

**PO No:** Not Available  
**Sampler Name:** [REDACTED]  
**ALS Program Ref:** SEVERSACFACENHI  
**Program Description:** CFA VEMTC Program - Central Highlands  
**Client Ref:** Central Highlands APWS

**Date Sampled:** 19-May-2022  
**Date Samples Received:** 19-May-2022  
**Date Issued:** 26-May-2022

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

The monochloramines component of Field Chlorine is not NATA accredited

### Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Analyst	[REDACTED]	Analyst
[REDACTED]	Analyst		

Samples collected by ALS according to procedure EN/67.  
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
 The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 22-43093  
 Report Number: 2842  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFACENHI  
 Program Description: CFA VEMTC Program - Central Highlands



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
143609	CH_APWS	Alternative Potable Water Supply	WATER	19/05/22 11:55

Analysis - Analyte

	Sample No. Site Code Units	143609 CH_APWS
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	3
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.4
EC (Field) - Electrical Conductivity (Field)	uS/cm	540
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	8.0
Redox (Field) - Redox Potential (Field)	mV	135.8
Temp (Field) - Temperature (Field)	°C	11.2
Field Cl2 - Total Chlorine (Field)	mg/L	0.06

A blank space indicates no test performed.