

CERTIFICATE OF ANALYSIS

Batch No: 22-53565
Final Report 19617

Page 1 of 2

Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

Laboratory Address: Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179
Phone: 03 8756 8000
Fax: 03 9763 1862
Contact: [REDACTED]

PO No: Not Available

Date Sampled: 14-Jul-2022

Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFACENHI

Date Samples Received: 11-Jul-2022
Date Issued: 22-Jul-2022

Program Description: CFA VEMTC Program - Central Highlands
Client Ref: Central Highlands APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

The monochloramines component of Field Chlorine is not NATA accredited

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Analyst	[REDACTED]	Analyst
[REDACTED]	Analyst		

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested

Batch No: 22-53565
 Report Number: 19617
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFACENHI
 Program Description: CFA VEMTC Program - Central Highlands



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7488190	CH_APWS	Alternative Potable Water Supply	WATER	14/07/22 14:15

Analysis - Analyte

	Sample No. Site Code Units	7488190 CH_APWS
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	6
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.3
EC (Field) - Electrical Conductivity (Field)	uS/cm	520
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	7.9
Redox (Field) - Redox Potential (Field)	mV	110.0
Temp (Field) - Temperature (Field)	°C	8.0
Field Cl2 - Total Chlorine (Field)	mg/L	0.12

A blank space indicates no test performed.