



CERTIFICATE OF ANALYSIS

Batch No:

22-56060

Final Report

20569

Client: Contact: Address:

Ground Floor

51 Clarke Street SOUTHBANK

Senversa Pty Ltd

VIC 3006 AUSTRALIA

Page 1 of 2

Scoresby Laboratory

Caribbean Business Park, 22 Dalmore Drive,

Scoresby, VIC 3179

03 8756 8000 03 9763 1862

Fax Contact:

Phone

Laboratory

Address

PO No:

Not Available

Date Sampled:

20-Jul-2022

Sampler Name: ALS Program Ref:

SEVERSACFAHUNT

Date Samples Received: Date Issued: 20-Jul-2022 27-Jul-2022

Program Description:

CFA VEMTC Program - Huntly

Client Ref:

CFA Huntly APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.					<u>e.</u>
Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

The monochloramines component of Field Chlorine is not NATA accredited

Signatories

Name	Title	Name	Title
	Client Manager		Team Leader Nutrients
	Analyst		Analyst
	Analyst		Process Co-ordinator

Samples collected by ALS according to procedure EN/67. Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Page 2 of 2

Batch No: Report Number: 22-56060 20569

Client:

Senversa Pty Ltd SEVERSACFAHUNT

ALS Program Ref: Program Description:

CFA VEMTC Program - Huntly



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7528948	HU_TA10	Main FTW Source	WATER	20/07/22 10:02

Analysis - Analyte	Sample No. Site Code Units	7528948 HU_TA10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/-2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	11.4
EC (Field) - Electrical Conductivity (Field)	uS/cm	240
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	8.4
Redox (Field) - Redox Potential (Field)	m∨	187.6
Temp (Field) - Temperature (Field)	°C	8.3
Field Cl2 - Total Chlorine (Field)	mg/L	0.05

A blank space indicates no test performed.