

CERTIFICATE OF ANALYSIS

Batch No: 22-58369
Final Report 31096

Page 1 of 2

Client: **Senversa Pty Ltd**

Laboratory

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Contact:

Address

Address:

Phone

03 8756 8000

Fax

03 9763 1862

Contact:

PO No: **Not Available**

Date Sampled:

29-Aug-2022

Sampler Name:

Date Samples Received:

30-Aug-2022

ALS Program Ref:

SEVERSACFALONG

Date Issued:

06-Sep-2022

Program Description:

CFA VEMTC Program - Longerenong

Client Ref:

CFA Longerenong APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

The monochloramines component of Field Chlorine is not NATA accredited

Signatories

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Client Manager		Team Leader Nutrients
	Technical Assistant		Analyst

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Page 2 of 2
 Batch No: 22-58369
 Report Number: 31096
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFALONG
 Program Description: CFA VEMTC Program - Longerenong



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7570853	LO_TA10	Agriculture Water	WATER	29/08/22 11:00

Analysis - Analyte

	Sample No. Site Code Units	7570853 LO_TA10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.2
EC (Field) - Electrical Conductivity (Field)	uS/cm	130
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	8.9
Redox (Field) - Redox Potential (Field)	mV	149.0
Temp (Field) - Temperature (Field)	°C	9.9
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05

A blank space indicates no test performed.