

CERTIFICATE OF ANALYSIS

Batch No: 22-64203
Final Report 31413

Page 1 of 2

Client: Senversa Pty Ltd

Laboratory Address

Traralgon Laboratory
 4/55 Hazelwood Road,
 Traralgon,
 VIC 3844

Contact: [REDACTED]

Phone Fax

03 5176 4170
 03 5176 4473

Address: [REDACTED]

Contact:

[REDACTED]

PO No: Not Available

Date Sampled: 31-Aug-2022

Sampler Name: [REDACTED]

Date Samples Received: 31-Aug-2022

ALS Program Ref: SEVERSACFAWSALE

Date Issued: 07-Sep-2022

Program Description: CFA VEMTC Program - West Sale

Client Ref: CFA West Sale APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
pH	WA005	Traralgon	Ps aeruginosa	MM528	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Signatories

Name	Title	Name	Title
[REDACTED]	Team Leader Nutrients	[REDACTED]	Senior Analyst

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7671573	WS_APWS	Alternative Potable Water Supply	WATER	31/08/22 11:10
7671574	WS_TWT	Treated Water Tank	WATER	31/08/22 11:25

Analysis - Analyte

	Sample No. Site Code Units	7671573 WS_APWS	7671574 WS_TWT
E.coli, Coliforms - E.coli	cfu/100mL	0	0
Enterolert - Enterococci	MPN/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0	0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
pH - pH, units	Units	7.5	7.7
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.9	10.6
EC (Field) - Electrical Conductivity (Field)	uS/cm	440	440
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05	0.20
Redox (Field) - Redox Potential (Field)	mV	140.5	126.4
Temp (Field) - Temperature (Field)	°C	11.8	12.1
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05	0.20

A blank space indicates no test performed.