

## CERTIFICATE OF ANALYSIS

**Batch No:** 22-69934  
*Final Report* 37357

Page 1 of 2

*Client:* Senversa Pty Ltd

*Contact:* [REDACTED]

*Address:* [REDACTED]

*Laboratory Address*

Traralgon Laboratory  
 4/55 Hazelwood Road,  
 Traralgon,  
 VIC 3844

*Phone Fax*

03 5176 4170  
 03 5176 4473

*Contact:*

[REDACTED]

*PO No:* Not Available

*Date Sampled:* 27-Sep-2022

*Sampler Name:* [REDACTED]

*Date Samples Received:* 27-Sep-2022

*ALS Program Ref:* SEVERSACFAWSALE

*Date Issued:* 05-Oct-2022

*Program Description:* CFA VEMTC Program - West Sale

*Client Ref:* CFA West Sale APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
pH	WA005	Traralgon	Ps aeruginosa	MM528	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.*

*Signatories*

Name	Title	Name	Title
[REDACTED]	Team Leader Nutrients Senior Analyst	[REDACTED]	Analyst

Samples collected by ALS according to procedure EN/67.  
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7772449	WS_APWS	Alternative Potable Water Supply	WATER	27/09/22 11:54
7772450	WS_TWT	Treated Water Tank	WATER	27/09/22 12:10

Analysis - Analyte

	Sample No. Site Code Units	7772449 WS_APWS	7772450 WS_TWT
E.coli, Coliforms - E.coli	cfu/100mL	0	0
Enterolert - Enterococci	MPN/100mL	6	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0	0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
pH - pH, units	Units	7.3	7.5
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.8	10.4
EC (Field) - Electrical Conductivity (Field)	uS/cm	430	440
Field Cl2 - Free Chlorine (Field)	mg/L	0.08	0.15
Redox (Field) - Redox Potential (Field)	mV	138.9	134.9
Temp (Field) - Temperature (Field)	°C	13.1	12.5
Field Cl2 - Total Chlorine (Field)	mg/L	0.16	0.17

A blank space indicates no test performed.