

CERTIFICATE OF ANALYSIS

Batch No: 22-77227
Final Report 49259

Page 1 of 2

Client: Senversa Pty Ltd

*Laboratory
Address*

Scoresby Laboratory
 Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179

Contact: [REDACTED]

*Phone
Fax*

03 8756 8000
 03 9763 1862

Address: [REDACTED]

Contact:

[REDACTED]

PO No: Not Available

Date Sampled: 18-Nov-2022

Sampler Name: [REDACTED]

Date Samples Received: 18-Nov-2022

ALS Program Ref: SEVERSACFABANG

Date Issued: 25-Nov-2022

Program Description: CFA VEMTC Program - Bangholme

Client Ref: CFA Bangholme APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Technical Assistant	[REDACTED]	Analyst

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
 Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
 The report shall not be reproduced, except in full and results relate only to the items tested.

Page 2 of 2
 Batch No: 22-77227
 Report Number: 49259
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFABANG
 Program Description: CFA VEMTC Program - Bangholme



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7905053	BA_APWS	Alternative Potable Water Source	WATER	18/11/22 10:35

Analysis - Analyte

	Sample No. Site Code Units	7905053 BA_APWS
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10
Legionella - Total Legionellae	cfu/mL	<10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.6
EC (Field) - Electrical Conductivity (Field)	uS/cm	170
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	7.2
Redox (Field) - Redox Potential (Field)	mV	115.6
Temp (Field) - Temperature (Field)	°C	16.6
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05

A blank space indicates no test performed.