

CERTIFICATE OF ANALYSIS

Batch No: 22-77206
Final Report 52983

Page 1 of 2

Client: Senversa Pty Ltd

Contact: [REDACTED]

Address: [REDACTED]

*Laboratory
Address*

Scoresby Laboratory
 Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179

*Phone
Fax*

03 8756 8000
 03 9763 1862

Contact:

[REDACTED]
 [REDACTED]
 [REDACTED]

PO No: Not Available

Date Sampled: 30-Nov-2022

Sampler Name: [REDACTED]

Date Samples Received: 01-Dec-2022

ALS Program Ref: SEVERSACFASUN

Date Issued: 09-Dec-2022

Program Description: CFA VEMTC Program - Sunraysia

Client Ref: CFA Sunraysia APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Team Leader Microbiology	[REDACTED]	Analyst

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
 Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
 The report shall not be reproduced, except in full and results relate only to the items tested.

Page 2 of 2
 Batch No: 22-77206
 Report Number: 52983
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFASUN
 Program Description: CFA VEMTC Program - Sunraysia



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7904739	SU_APWS	Alternative Potable Water Supply Tank	WATER	30/11/22 09:00

Analysis - Analyte

	Sample No. Site Code Units	7904739 SU_APWS
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10
Legionella - Total Legionellae	cfu/mL	<10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	8.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	270
Field Cl2 - Free Chlorine (Field)	mg/L	1.0
pH (Field) - pH (Field)	Units	7.6
Redox (Field) - Redox Potential (Field)	mV	648.5
Temp (Field) - Temperature (Field)	°C	21.4
Field Cl2 - Total Chlorine (Field)	mg/L	1.1

A blank space indicates no test performed.