

CERTIFICATE OF ANALYSIS

Batch No: 22-84899
Replacement Report 56515
This report replaces Report Number: 56509
Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: [REDACTED]

Page 1 of 2

Laboratory Address
 Traralgon Laboratory
 4/55 Hazelwood Road,
 Traralgon,
 VIC 3844

Phone 03 5176 4170
Fax 03 5176 4473

Contact: [REDACTED]
 [REDACTED]

PO No: Not Available
Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFAWSALE
Program Description: CFA VEMTC Program - West Sale
Client Ref: CFA West Sale APWS

Date Sampled: 13-Dec-2022
Date Samples Received: 13-Dec-2022
Date Issued: 23-Dec-2022

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
Legionella	MM527	Scoresby	pH	WA005	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Signatories

Name	Title	Name	Title
[REDACTED]	Team Leader Nutrients Analyst	[REDACTED]	Senior Analyst

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8083809	WS_APWS	Alternative Potable Water Supply	WATER	13/12/22 11:45
8083811	WS_TWT	Treated Water Tank	WATER	13/12/22 12:10

Analysis - Analyte

	Sample No. Site Code Units	8083809 WS_APWS	8083811 WS_TWT
Legionella - Legionella pneumophila	cfu/mL	<10	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10	<10
Legionella - Total Legionellae	cfu/mL	<10	<10
E.coli, Coliforms - Coliforms	cfu/100mL	0	0
E.coli, Coliforms - E.coli	cfu/100mL	0	0
Enterolert - Enterococci	MPN/100mL	0	0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
pH - pH, units	Units	7.6	7.9
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.1	9.3
EC (Field) - Electrical Conductivity (Field)	uS/cm	460	410
Field Cl2 - Free Chlorine (Field)	mg/L	2.2	1.9
Redox (Field) - Redox Potential (Field)	mV	435.1	466.0
Temp (Field) - Temperature (Field)	°C	16.6	16.5
Field Cl2 - Total Chlorine (Field)	mg/L	2.5	2.0

A blank space indicates no test performed.