



CERTIFICATE OF ANALYSIS

Batch No: 23-11756

Final Report 70226

Client: Senversa Pty Ltd

Contact:

Address: Ground Floor

51 Clarke Street SOUTHBANK

VIC 3006

AUSTRALIA

Page 1 of 2

Bendigo Laboratory 15 Wellsford Drive,

East Bendigo, VIC 3550

03 5441 0700

Contact:

Laboratory

Address

Phone

Fax

PO No: Not Available

Sampler Name:

ALS Program Ref: SEVERSACFAHUNT

Program Description: CFA VEMTC Program - Huntly

Client Ref: CFA Huntly APWS

Date Sampled: 09-Feb-2023

Date Samples Received: 09-Feb-2023

Date Issued: 18-Feb-2023

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service

	THE HADIT (III) BOICE	The hadri (ii) below indicated that severed by 14 th tacerdatation in the performance of the service.					
Analysis	Method	Laboratory	Analysis	Method	Laboratory		
Field Cl2	EN67.2	Bendigo	DO (Field)	EN67.2	Bendigo		
EC (Field)	EN67.2	Bendigo	pH (Field)	EN67.2	Bendigo		
Redox (Field)	# EA075FD	Bendigo	Temp (Field)	EN67.2	Bendigo		
BOD5	WP030	Scoresby	Colilert (2000)	MM514	Scoresby		
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby		
SS at 104+/- 2°C	WA025	Scoresby					

Signatories



Samples collected by ALS according to procedure EN/67. Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila Samples are tested within holding time unless otherwise stated.

Page 2 of 2 23-11756

 Batch No:
 23-117

 Report Number:
 70226

Client: Senversa Pty Ltd
ALS Program Ref: SEVERSACFAHUNT

Program Description: CFA VEMTC Program - Huntly



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8268814	HU_TA10	Main FTW Source	WATER	09/02/23 12:05

Analysis - Analyte	Sample No. Site Code Units	8268814 HU_TA10
Temp (Field) - Temperature (Field)	С	22.9
pH (Field) - pH (Field)	Units	8.4
EC (Field) - Electrical Conductivity (Field)	uS/cm	260
DO (Field) - Dissolved Oxygen (Field)	mg/L	7.9
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05
Redox (Field) - Redox Potential (Field)	mV	222.5
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliform	MPN/100mL	130
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	1
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.