

## CERTIFICATE OF ANALYSIS

**Batch No:** 23-23389  
*Final Report* 88811

Page 1 of 2

**Client:** Senversa Pty Ltd  
**Contact:** [REDACTED]  
**Address:** Ground Floor  
51 Clarke Street  
SOUTHBANK  
VIC  
3006  
AUSTRALIA

*Laboratory  
Address*

Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179

*Phone  
Fax*

03 8756 8000  
03 9763 1862

**Contact:**

[REDACTED]  
[REDACTED]  
[REDACTED]

**PO No:** Not Available

**Date Sampled:** 27-Apr-2023

**Sampler Name:** [REDACTED]

**Date Samples Received:** 27-Apr-2023

**ALS Program Ref:** SEVERSACFABANG

**Date Issued:** 05-May-2023

**Program Description:** CFA VEMTC Program - Bangholme

**Client Ref:** CFA Bangholme APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

### Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Page 2 of 2  
 Batch No: 23-23389  
 Report Number: 88811  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFABANG  
 Program Description: CFA VEMTC Program - Bangholme



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8459481	BA_APWS	Alternative Potable Water Source	WATER	27/04/23 11:30

Analysis - Analyte	Sample No. Site Code Units	8459481 BA_APWS
Temp (Field) - Temperature (Field)	°C	17.1
pH (Field) - pH (Field)	Units	8.2
EC (Field) - Electrical Conductivity (Field)	uS/cm	110
DO (Field) - Dissolved Oxygen (Field)	mg/L	8.9
Field Cl2 - Free Chlorine (Field)	mg/L	1.7
Field Cl2 - Total Chlorine (Field)	mg/L	2.5
Redox (Field) - Redox Potential (Field)	mV	666.3
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.