

CERTIFICATE OF ANALYSIS

Batch No: 23-34636
Final Report 96888

Page 1 of 2

Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

Laboratory Address
Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179
Phone 03 8756 8000
Fax 03 9763 1862
Contact: [REDACTED]

PO No: Not Available

Date Sampled: 06-Jun-2023

Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFACENHI

Date Samples Received: 07-Jun-2023
Date Issued: 14-Jun-2023

Program Description: CFA VEMTC Program - Central Highlands
Client Ref: Central Highlands APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

| Analysis | Method | Laboratory | Analysis | Method | Laboratory |
|------------------|-----------|------------|-------------------|--------|------------|
| Field Cl2 | EN67.2 | Scoresby | DO (Field) | EN67.2 | Scoresby |
| EC (Field) | EN67.2 | Scoresby | pH (Field) | EN67.2 | Scoresby |
| Redox (Field) | # EA075FD | Scoresby | Temp (Field) | EN67.2 | Scoresby |
| BOD5 | WP030 | Scoresby | E.coli, Coliforms | MM698 | Scoresby |
| Enterolert | MM517 | Scoresby | Legionella | MM527 | Scoresby |
| SS at 104+/- 2°C | WA025 | Scoresby | | | |

Signatories

| Name | Title | Name | Title |
|------------|------------|------------|------------|
| [REDACTED] | [REDACTED] | [REDACTED] | [REDACTED] |

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 23-34636
 Report Number: 96888
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFACENHI
 Program Description: CFA VEMTC Program - Central Highlands



| Sample No | Site Code | Site Description | Sample Type | Sampled Date/Time |
|-----------|-----------|---|-------------|-------------------|
| 8651952 | CH_APWS | NONE - Alternative Potable Water Supply | WATER | 06/06/23 14:00 |

| Analysis - Analyte | Sample No. Site Code Units | 8651952 CH_APWS |
|---|----------------------------------|--------------------|
| Temp (Field) - Temperature (Field) | C | 10.8 |
| pH (Field) - pH (Field) | Units | 7.8 |
| EC (Field) - Electrical Conductivity (Field) | uS/cm | 390 |
| DO (Field) - Dissolved Oxygen (Field) | mg/L | 9.7 |
| Field Cl2 - Free Chlorine (Field) | mg/L | <0.05 |
| Field Cl2 - Total Chlorine (Field) | mg/L | 0.14 |
| Redox (Field) - Redox Potential (Field) | mV | 170.0 |
| BOD5 - Biochemical Oxygen Demand, 5 Day | mg/L | <2 |
| SS at 104+/- 2 C - Suspended Solids | mg/L | <2 |
| E.coli, Coliforms - Coliforms | cfu/100mL | 0 |
| E.coli, Coliforms - E.coli | cfu/100mL | 0 |
| Enterolert - Enterococci | MPN/100mL | 0 |
| Legionella - Total Legionellae | cfu/mL | <10 |
| Legionella - Legionella pneumophila | cfu/mL | <10 |
| Legionella - Legionella Species other than L. pneumophila | cfu/mL | <10 |

A blank space indicates no test performed.