



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: **24-60640**

Final Report

220688

Page 1 of 2

Client: **Veolia Environmental Services**

Contact:

[REDACTED]

Address:

Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory

Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Phone

03 8756 8000

Fax

03 9763 1862

Contact:

[REDACTED]

[REDACTED]

[REDACTED]

PO No: **7300346657**

Date Sampled:

02-Oct-2024

Sampler Name:

[REDACTED]

Date Samples Received:

02-Oct-2024

ALS Program Ref:

VEOLIA_CFA

Date Issued:

10-Oct-2024

Program Description:

CFA VEMTC

Client Ref:

CFA West Sale APWS

[The hash \(#\) below indicates methods not covered by NATA accreditation in the performance of this service.](#)

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Analyst
[REDACTED]	Analyst	[REDACTED]	Analyst
[REDACTED]	Analyst		

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 24-60640
 Report Number: 220688
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10344204	WTP4-APWS	Alternative Potable Water Supply	WATER	02/10/24 09:00

Analysis - Analyte		Sample No. Site Code Units	10344204 WTP4-APWS
Temp. - Water Temperature (CS)		°C	12.4
pH - pH (CS)		Units	7.41
Field Chlorine - Free Chlorine (CS)		mg/L	1.55
Field Chlorine - Total Chlorine (CS)		mg/L	1.69
BOD5 - Biochemical Oxygen Demand, 5 Day		mg/L	<2
SS at 104+/- 2°C - Suspended Solids		mg/L	<2
E.coli, Coliforms - Coliforms		cfu/100mL	0
E.coli, Coliforms - E.coli		cfu/100mL	0
Enterolert - Enterococci		MPN/100mL	0
Legionella - Total Legionellae		cfu/mL	<10
Legionella - Legionella pneumophila		cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila		cfu/mL	<10

A blank space indicates no test performed.