



Accreditation No. 992  
Accredited for compliance with  
ISO/IEC 17025 - Testing

## CERTIFICATE OF ANALYSIS

Batch No: **24-66333**

Final Report

**226564**

Page 1 of 2

Client: **Veolia Environmental Services**

Contact:

[REDACTED]

Address:

Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

Laboratory  
Address

Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179

Phone  
Fax

03 8756 8000  
03 9763 1862

Contact:

[REDACTED]

[REDACTED]

[REDACTED]

PO No: **7300346657**

Date Sampled: **30-Oct-2024**

Sampler Name:

[REDACTED]

Date Samples Received: **30-Oct-2024**

ALS Program Ref:

**VEOLIA\_CFA**

Date Issued:

**07-Nov-2024**

Program Description:

**CFA VEMTC**

Client Ref:

**CFA Bangholme APWS**

[The hash \(#\) below indicates methods not covered by NATA accreditation in the performance of this service.](#)

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

### Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Microbiology
[REDACTED]	Analyst	[REDACTED]	Chemist
[REDACTED]	Analyst		

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2  
 Batch No: 24-66333  
 Report Number: 226564  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10446094	WTP5-APWS	Alternative Potable Water Supply	WATER	30/10/24 12:30

Analysis - Analyte		Sample No. Site Code Units	10446094 WTP5-APWS
Temp. - Water Temperature (CS)		°C	18.1
pH - pH (CS)		Units	8.17
Field Chlorine - Free Chlorine (CS)		mg/L	0.57
Field Chlorine - Total Chlorine (CS)		mg/L	0.60
BOD5 - Biochemical Oxygen Demand, 5 Day		mg/L	<2
SS at 104+/- 2°C - Suspended Solids		mg/L	<2
E.coli, Coliforms - Coliforms		cfu/100mL	0
E.coli, Coliforms - E.coli		cfu/100mL	0
Enterolert - Enterococci		MPN/100mL	0
Legionella - Total Legionellae		cfu/mL	<10
Legionella - Legionella pneumophila		cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila		cfu/mL	<10

A blank space indicates no test performed.