



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: **24-72073**

Final Report

235603

Page 1 of 2

Client: **Veolia Environmental Services**

Contact:

Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory

Address

Wangaratta Laboratory
48 Faithfull Street,
Wangaratta,
VIC 3677.

Phone

Fax

03 5722 2688

03 5722 4727

Contact:

PO No: **7300346657**

Sampler Name:

ALS Program Ref: **VEOLIA_CFA**

Date Sampled:

04-Dec-2024

Date Samples Received:

04-Dec-2024

Date Issued:

13-Dec-2024

Program Description: **CFA VEMTC**

Client Ref: **CFA Wangaratta APWS**

[The hash \(#\) below indicates methods not covered by NATA accreditation in the performance of this service.](#)

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Wangaratta	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Wangaratta
E.coli, Coliforms	MM698	Wangaratta	Enterolert	MM517	Wangaratta
Legionella	MM527	Wangaratta	SS at 104+/- 2°C	WA025	Wangaratta

Signatories

Name	Title	Name	Title
	Client Manager		Analyst
	Laboratory Co-ordinator		
	Wangaratta		

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 24-72073
 Report Number: 235603
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10573323	WTP2-APWS	Alternative Potable Water Supply		04/12/24 08:45

Analysis - Analyte		Sample No. Site Code Units	10573323 WTP2-APWS
Temp. - Water Temperature (CS)		°C	22.9
pH - pH (CS)		Units	7.75
Field Chlorine - Free Chlorine (CS)		mg/L	0.92
Field Chlorine - Total Chlorine (CS)		mg/L	1.03
BOD5 - Biochemical Oxygen Demand, 5 Day		mg/L	<2
SS at 104+/- 2°C - Suspended Solids		mg/L	4
E.coli, Coliforms - Coliforms		cfu/100mL	0
E.coli, Coliforms - E.coli		cfu/100mL	0
Enterolert - Enterococci		MPN/100mL	2
Legionella - Total Legionellae		cfu/mL	<10
Legionella - Legionella pneumophila		cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila		cfu/mL	<10

A blank space indicates no test performed.