



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: 25-13567

Final Report

252589

Page 1 of 2

Client: Veolia Environmental Services

Contact:

Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory

Address

Wangaratta Laboratory

48 Faithfull Street,
Wangaratta,
VIC 3677.

Phone

Fax

03 5722 2688

03 5722 4727

Contact:

PO No: 7300438899

Date Sampled:

11-Feb-2025

Sampler Name:

ALS Program Ref: VEOLIA_CFA

Date Samples Received:

11-Feb-2025

Date Issued:

19-Feb-2025

Program Description: CFA VEMTC

Client Ref: CFA Wangaratta APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

| Analysis | Method | Laboratory | Analysis | Method | Laboratory |
|-------------------|----------|------------|------------------|----------|------------|
| Field Chlorine | # CLIENT | Wangaratta | pH | # CLIENT | Scoresby |
| Temp. | # CLIENT | Scoresby | BOD5 | WP030 | Wangaratta |
| E.coli, Coliforms | MM698 | Wangaratta | Enterolert | MM517 | Wangaratta |
| Legionella | MM527 | Wangaratta | SS at 104+/- 2°C | WA025 | Wangaratta |

Signatories

| Name | Title | Name | Title |
|------|-------------------------|------|---------|
| | Client Manager | | Analyst |
| | Laboratory Co-ordinator | | |
| | Wangaratta | | |

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 25-13567
 Report Number: 252589
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



| Sample No | Site Code | Site Description | Sample Type | Sampled Date/Time |
|-----------|-----------|----------------------------------|-------------|-------------------|
| 10819910 | WTP2-APWS | Alternative Potable Water Supply | | 11/02/25 11:30 |

| Analysis - Analyte | | Sample No. Site Code Units | 10819910 WTP2-APWS |
|---|--|----------------------------------|-----------------------|
| Temp. - Water Temperature (CS) | | °C | 27.5 |
| pH - pH (CS) | | Units | 8.40 |
| Field Chlorine - Free Chlorine (CS) | | mg/L | 2.24 |
| Field Chlorine - Total Chlorine (CS) | | mg/L | 2.56 |
| BOD5 - Biochemical Oxygen Demand, 5 Day | | mg/L | <2 |
| SS at 104+/- 2°C - Suspended Solids | | mg/L | 12 |
| E.coli, Coliforms - Coliforms | | cfu/100mL | 0 |
| E.coli, Coliforms - E.coli | | cfu/100mL | 0 |
| Enterolert - Enterococci | | MPN/100mL | 6 |
| Legionella - Total Legionellae | | cfu/mL | <10 |
| Legionella - Legionella pneumophila | | cfu/mL | <10 |
| Legionella - Legionella Species other than L. pneumophila | | cfu/mL | <10 |

A blank space indicates no test performed.