



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: **25-15039**

Interim Report

252667

Page 1 of 2

Client: **Veolia Environmental Services**

Contact:

Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory

Address

Wangaratta Laboratory
48 Faithfull Street,
Wangaratta,
VIC 3677.

Phone

Fax

03 5722 2688
03 5722 4727

Contact:

PO No: **7300438899**

Date Sampled: **18-Feb-2025**

Sampler Name:

ALS Program Ref: **VEOLIA_CFA**

Date Samples Received: **18-Feb-2025**

Date Issued: **19-Feb-2025**

Program Description: **CFA VEMTC**

Client Ref: **CFA Wangaratta APWS**

[The hash \(#\) below indicates methods not covered by NATA accreditation in the performance of this service.](#)

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Wangaratta	Colilert (2000)	MM514	Wangaratta
Enterolert	MM517	Wangaratta	Legionella	MM527	Wangaratta

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Signatories

Name	Title	Name	Title
	Laboratory Co-ordinator Wangaratta		

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
Batch No: 25-15039
Report Number: 252667
Client: Veolia Environmental Services
ALS Program Ref: VEOLIA_CFA
Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10842697	WTP2-APWS	Alternative Potable Water Supply		18/02/25 10:00

Analysis - Analyte		Sample No. Site Code Units	10842697 WTP2-APWS
Field Chlorine - Free Chlorine (CS)		mg/L	Pending
Field Chlorine - Total Chlorine (CS)		mg/L	Pending
Colilert (2000) - Coliform		MPN/100mL	0
Colilert (2000) - E.coli		MPN/100mL	0
Enterolert - Enterococci		MPN/100mL	0
Legionella - Total Legionellae		cfu/mL	Pending
Legionella - Legionella pneumophila		cfu/mL	Pending
Legionella - Legionella Species other than L. pneumophila		cfu/mL	Pending

A blank space indicates no test performed.