



Accreditation No. 992  
Accredited for compliance with  
ISO/IEC 17025 - Testing

## CERTIFICATE OF ANALYSIS

Batch No: 25-25232

Final Report

267365

Page 1 of 2

Client: Veolia Environmental Services

Contact:

Address: Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

Laboratory

Address

Wangaratta Laboratory

48 Faithfull Street,  
Wangaratta,  
VIC 3677.

Phone

Fax

03 5722 2688

03 5722 4727

Contact:

PO No: 7300438899

Date Sampled:

07-Apr-2025

Sampler Name:

ALS Program Ref: VEOLIA\_CFA

Date Samples Received:

07-Apr-2025

Date Issued:

15-Apr-2025

Program Description:

CFA VEMTC

Client Ref:

CFA Wangaratta APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Wangaratta	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Wangaratta
E.coli, Coliforms	MM698	Wangaratta	Enterolert	MM517	Wangaratta
Legionella	MM527	Wangaratta	SS at 104+/- 2°C	WA025	Wangaratta

### Signatories

Name	Title	Name	Title
	Client Manager		Analyst
	Laboratory Co-ordinator		
	Wangaratta		

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2  
 Batch No: 25-25232  
 Report Number: 267365  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
11022094	WTP2-APWS	Alternative Potable Water Supply	WATER	07/04/25 11:30

Analysis - Analyte		Sample No. Site Code Units	11022094 WTP2-APWS
Temp. - Water Temperature (CS)		°C	19.2
pH - pH (CS)		Units	7.33
Field Chlorine - Free Chlorine (CS)		mg/L	1.22
Field Chlorine - Total Chlorine (CS)		mg/L	1.56
BOD5 - Biochemical Oxygen Demand, 5 Day		mg/L	<2
SS at 104+/- 2°C - Suspended Solids		mg/L	2
E.coli, Coliforms - Coliforms		cfu/100mL	0
E.coli, Coliforms - E.coli		cfu/100mL	0
Enterolert - Enterococci		MPN/100mL	0
Legionella - Total Legionellae		cfu/mL	<10
Legionella - Legionella pneumophila		cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila		cfu/mL	<10

A blank space indicates no test performed.