



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: 25-33916

Final Report

277736

Page 1 of 2

Client: Veolia Environmental Services

Contact:

Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Phone
Fax
Contact:

03 8756 8000
03 9763 1862

PO No: 7300438899

Date Sampled: 20-May-2025

Sampler Name:

ALS Program Ref: VEOLIA_CFA

Date Samples Received: 20-May-2025

Date Issued: 28-May-2025

Program Description: CFA VEMTC

Client Ref: CFA Bangholme APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterococci (mEI)	MM690	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
	Laboratory Technician		Analyst
	Client Manager		Analyst

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 25-33916
 Report Number: 277736
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
11168609	WTP5-APWS	Alternative Potable Water Supply	WATER	20/05/25 11:30

Analysis - Analyte		Sample No. Site Code Units	11168609 WTP5-APWS
Temp. - Water Temperature (CS)		°C	16.5
pH - pH (CS)		Units	8.23
Field Chlorine - Free Chlorine (CS)		mg/L	0.99
Field Chlorine - Total Chlorine (CS)		mg/L	1.06
BOD5 - Biochemical Oxygen Demand, 5 Day		mg/L	<2
SS at 104+/- 2°C - Suspended Solids		mg/L	<2
E.coli, Coliforms - Coliforms		cfu/100mL	0
E.coli, Coliforms - E.coli		cfu/100mL	0
Enterococci (mEI) - Enterococci		cfu/100mL	0
Legionella - Total Legionellae		cfu/mL	<10
Legionella - Legionella pneumophila		cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila		cfu/mL	<10

A blank space indicates no test performed.