



Accreditation No. 992  
Accredited for compliance with  
ISO/IEC 17025 - Testing

## CERTIFICATE OF ANALYSIS

Batch No: 25-34440

Final Report

278741

Page 1 of 2

Client: Veolia Environmental Services

Contact:

Address: Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

Laboratory  
Address

Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179

Phone

03 8756 8000

Fax

03 9763 1862

Contact:

PO No: 7300438899

Date Sampled:

22-May-2025

Sampler Name:

ALS Program Ref: VEOLIA\_CFA

Date Samples Received:

22-May-2025

Date Issued:

02-Jun-2025

Program Description:

CFA VEMTC

Client Ref:

CFA Huntly APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

| Analysis          | Method   | Laboratory | Analysis          | Method   | Laboratory |
|-------------------|----------|------------|-------------------|----------|------------|
| Field Chlorine    | # CLIENT | Scoresby   | pH                | # CLIENT | Scoresby   |
| Temp.             | # CLIENT | Scoresby   | BOD5              | WP030    | Scoresby   |
| E.coli, Coliforms | MM698    | Scoresby   | Enterococci (mEI) | MM690    | Scoresby   |
| Legionella        | MM527    | Scoresby   | SS at 104+/- 2°C  | WA025    | Scoresby   |

### Signatories

| Name | Title                 | Name | Title   |
|------|-----------------------|------|---------|
|      | Laboratory Technician |      | Analyst |
|      | Client Manager        |      | Analyst |
|      | Analyst               |      |         |

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2  
 Batch No: 25-34440  
 Report Number: 278741  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



| Sample No | Site Code | Site Description                 | Sample Type | Sampled Date/Time |
|-----------|-----------|----------------------------------|-------------|-------------------|
| 11176922  | WTP7-APWS | Alternative Potable Water Supply | WATER       | 22/05/25 12:45    |

| Analysis - Analyte                                        |  | Sample No.<br>Site Code<br>Units | 11176922<br>WTP7-APWS |
|-----------------------------------------------------------|--|----------------------------------|-----------------------|
| Temp. - Water Temperature (CS)                            |  | °C                               | 12.5                  |
| pH - pH (CS)                                              |  | Units                            | 7.53                  |
| Field Chlorine - Free Chlorine (CS)                       |  | mg/L                             | 3.9                   |
| Field Chlorine - Total Chlorine (CS)                      |  | mg/L                             | 4.8                   |
| BOD5 - Biochemical Oxygen Demand, 5 Day                   |  | mg/L                             | <2                    |
| SS at 104+/- 2°C - Suspended Solids                       |  | mg/L                             | <2                    |
| E.coli, Coliforms - Coliforms                             |  | cfu/100mL                        | 0                     |
| E.coli, Coliforms - E.coli                                |  | cfu/100mL                        | 0                     |
| Enterococci (mEI) - Enterococci                           |  | cfu/100mL                        | 0                     |
| Legionella - Total Legionellae                            |  | cfu/mL                           | <10                   |
| Legionella - Legionella pneumophila                       |  | cfu/mL                           | <10                   |
| Legionella - Legionella Species other than L. pneumophila |  | cfu/mL                           | <10                   |

A blank space indicates no test performed.