



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: 25-39914

Final Report

283367

Page 1 of 2

Client:

Contact:

Address:

Veolia Environmental Services

Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Phone

03 8756 8000

Fax

03 9763 1862

Contact:

PO No:

7300438899

Date Sampled:

17-Jun-2025

Sampler Name:

[REDACTED]

Date Samples Received:

18-Jun-2025

ALS Program Ref:

VEOLIA_CFA

Date Issued:

25-Jun-2025

Program Description:

CFA VEMTC

Client Ref:

CFA Sunraysia APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
[REDACTED]	Laboratory Technician	[REDACTED]	Analyst
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 25-39914
 Report Number: 283367
 Client:
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
11275827	WTP3-APWS	Alternative Potable Water Supply	WATER	17/06/25 10:30

Analysis - Analyte		Sample No. Site Code Units	11275827 WTP3-APWS
Temp. - Water Temperature (CS)	°C		12.50
pH - pH (CS)	Units		8.25
Field Chlorine - Free Chlorine (CS)	mg/L		0.50
Field Chlorine - Total Chlorine (CS)	mg/L		0.67
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L		<2
SS at 104+/- 2°C - Suspended Solids	mg/L		<2
E.coli, Coliforms - Coliforms	cfu/100mL		0
E.coli, Coliforms - E.coli	cfu/100mL		0
Enterolert - Enterococci	MPN/100mL		0
Legionella - Total Legionellae	cfu/mL		<10
Legionella - Legionella pneumophila	cfu/mL		<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL		<10

A blank space indicates no test performed.