



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: 25-58354

Final Report

303151

Page 1 of 2

Client: [REDACTED]

Contact: [REDACTED]

Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Phone

03 8756 8000

Fax

03 9763 1862

Contact:

[REDACTED]

[REDACTED]

PO No: [REDACTED]

Date Sampled: 10-Sep-2025

Sampler Name: [REDACTED]

Date Samples Received: 11-Sep-2025

ALS Program Ref: VEOLIA_CFA

Date Issued: 22-Sep-2025

Program Description: CFA VEMTC

Client Ref: CFA Sunraysia APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterococci (mEI)	MM690	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
[REDACTED]	Laboratory Technician	[REDACTED]	Analyst
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 25-58354
 Report Number: 303151
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
11620415	WTP3-APWS	Alternative Potable Water Supply	WATER	10/09/25 10:00

Analysis - Analyte		Sample No. Site Code Units	11620415 WTP3-APWS
Temp. - Water Temperature (CS)		°C	16.4
pH - pH (CS)		Units	7.40
Field Chlorine - Free Chlorine (CS)		mg/L	1.01
Field Chlorine - Total Chlorine (CS)		mg/L	1.16
BOD5 - Biochemical Oxygen Demand, 5 Day		mg/L	<2
SS at 104+/- 2°C - Suspended Solids		mg/L	<2
E.coli, Coliforms - Coliforms		cfu/100mL	0
E.coli, Coliforms - E.coli		cfu/100mL	0
Enterococci (mEI) - Enterococci		cfu/100mL	0
Legionella - Total Legionellae		cfu/mL	<10
Legionella - Legionella pneumophila		cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila		cfu/mL	<10

A blank space indicates no test performed.