

CERTIFICATE OF ANALYSIS

Batch No:	17-36246	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	642745	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	CFA Training Ground - Huntly Campus	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>	PO Box 383	<i>Phone</i>	03 5441 0700
<i>Address:</i>	HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
	Not Available	<i>Contact:</i>	Bendigo Laboratory Manager
	CFABGO		
<i>PO No:</i>	Analysis for Amiad Water Systems	<i>Date Sampled:</i>	21-Aug-2017
<i>Sampler Name:</i>	Analysis	<i>Date Samples Received:</i>	21-Aug-2017
<i>ALS Program Ref:</i>		<i>Date Issued:</i>	28-Aug-2017
<i>Program Description:</i>			
<i>Client Ref:</i>			

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.
 Analysis conducted outside holding time due to late arrival or delayed extraction/analysis. Based on APHA, VICEPA, AS & NEPM. Results are approximate and for indicative purposes only.
 Late Sample Arrival - Ps aeruginosa[5312226,5312227,5312228,5312229]

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Bendigo Laboratory Manager		Team Leader Microbiology
	Process Co-ordinator		



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

Samples collected by ALS according to procedure EN/67.
 Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5312226		Tank No 8	WATER	21/08/17 10:18
5312227		Tank No 9	WATER	21/08/17 10:15
5312228		Tank No 10	WATER	21/08/17 10:25
5312229		Hydrant	WATER	21/08/17 10:20

Analysis - Analyte	Sample No. Site Code Units	5312226	5312227	5312228	5312229
		BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0	0

A blank space indicates no test performed.