

CERTIFICATE OF ANALYSIS

Batch No:	17-38425	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	643343	<i>Laboratory</i>	Traralgon Laboratory
<i>Client:</i>	CFA West Sale Training Ground	<i>Address</i>	4/55 Hazelwood Road, Traralgon, VIC 3844
<i>Contact:</i>	PO Box 1212	<i>Phone</i>	03 5176 4170
<i>Address:</i>	SALE VIC 3850	<i>Fax</i>	03 5176 4473
		<i>Contact:</i>	Client Manager
	Not Available		24-Aug-2017
<i>PO No:</i>		<i>Date Sampled:</i>	24-Aug-2017
<i>Sampler Name:</i>	CFATRA	<i>Date Samples Received:</i>	30-Aug-2017
<i>ALS Program Ref:</i>		<i>Date Issued:</i>	
<i>Program Description:</i>	Analysis for CFA West Sale Training Ground - Amiad Water Systems		
<i>Client Ref:</i>	WQMP		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Scoresby	Colilert (2000)	MM514	Traralgon
Enterococci	MM572	Traralgon	pH	WA005	Traralgon
Ps aeruginosa	MM528	Traralgon	SS at 104+/- 2°C	WA025	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Team Leader Nutrients		Analyst
	Traralgon Laboratory Manager		

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5328721		Tank Supply to Fire Service	WATER	24/08/17 13:36
5328722		Tank Supply to Amenities	WATER	24/08/17 13:30

Analysis - Analyte	Sample No.	5328721	5328722
	Site Code Units		
pH - pH, units	Units	7.7	7.5
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	2
SS at 104+/- 2°C - Suspended Solids	mg/L	7	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterococci - Enterococci	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.