

CERTIFICATE OF ANALYSIS

Batch No:	17-42360	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	650650	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
			09-Oct-2017
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	09-Oct-2017
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	12-Oct-2017
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	WQMP		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Alg. ScCnt	MB006	Scoresby	Colilert (2000)	MM514	Scoresby
Ps aeruginosa	MM528	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Manager Botany		Team Leader Microbiology
	Analyst		



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5360888	CFAB02	South MegalitreTank	WATER	09/10/17 14:10
5360889	CFAB03	North MegalitreTank	WATER	09/10/17 13:30

Analysis - Analyte	Sample No. Site Code Units	5360888 CFAB02	5360889 CFAB03
	Alg. ScCnt - Algal analyses		NR IND
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

IND Reported independently on separate report

A blank space indicates no test performed.