



CERTIFICATE OF ANALYSIS

Batch No: 17-48640
Final Report 655869

Client: Country Fire Authority

Contact:

Address: PO Box 717
 PATTERSON LAKES VIC 3197

Page Page 1 of 2

Laboratory Scoresby Laboratory
Address Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179

Phone 03 8756 8000
Fax 03 9763 1862

PO No: Not Available

Sampler Name:

ALS Program Ref: CFA

Program Description: Miscellaneous Analyses

Client Ref: WQMP

Contact: Client Manager
08-Nov-2017

Date Sampled: 08-Nov-2017

Date Samples Received: 13-Nov-2017

Date Issued:

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Team Leader Microbiology		Analyst

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Measurement Uncertainties values for your compliance results are available at this link



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5413004	CFAB02	South MegalitreTank	WATER	08/11/17 12:25
5413005	CFAB03	North MegalitreTank	WATER	08/11/17 12:50

Analysis - Analyte	Sample No. Site Code Units	5413004 CFAB02	5413005 CFAB03
	Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.