

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>17-52828</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>660534</b>	<i>Laboratory</i>	Geelong Laboratory
<i>Client:</i>	<b>CFA</b>	<i>Address</i>	49 Carr Street, Geelong, VIC 3220
<i>Contact:</i>		<i>Phone</i>	03 5246 9403
<i>Address:</i>	PO Box 701 MT WAVERLEY VIC 3149	<i>Fax</i>	
		<i>Contact:</i>	Client Manager
 <i>PO No:</i>	 <b>Not Available</b>	<i>Date Sampled:</i>	<b>28-Nov-2017</b>
<i>Sampler Name:</i>	<b>Client</b>	<i>Date Samples Received:</i>	<b>29-Nov-2017</b>
<i>ALS Program Ref:</i>	<b>CFAGEE</b>	<i>Date Issued:</i>	<b>04-Dec-2017</b>
<i>Program Description:</i>	<b>Analysis for CFA Geelong - Amiad Water Systems</b>		
<i>Client Ref:</i>	<b>Penshurst Boost Point</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Geelong	Colilert (200)	MM514	Geelong
Ps aeruginosa	MM528	Geelong	SS at 104+/- 2°C	WA025	Geelong

Analysis conducted outside holding time due to late arrival or delayed extraction/analysis. Based on APHA, VICEPA, AS & NEPM. Results are approximate and for indicative purposes only.

*Late Analysis - BOD5[5447815]*

### Signatories

*These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11*

Name	Title	Name	Title
	<b>Senior Chemist</b>		<b>Analyst</b>



Samples not collected by ALS and are tested as received.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5447815		Boost Point	WATER	28/11/17 12:00

Analysis - Analyte	Sample No. Site Code Units	5447815
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (200) - E.coli MPN Colilert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

*A blank space indicates no test performed.*