

CERTIFICATE OF ANALYSIS

Batch No:	17-54453	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	665733	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	CFA Training Ground - Huntly Campus	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>	PO Box 383	<i>Phone</i>	03 5441 0700
<i>Address:</i>	HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
		<i>Contact:</i>	Bendigo Laboratory Manager
	Not Available		18-Dec-2017
<i>PO No:</i>		<i>Date Sampled:</i>	18-Dec-2017
<i>Sampler Name:</i>	CFABGO	<i>Date Samples Received:</i>	27-Dec-2017
<i>ALS Program Ref:</i>	Analysis for Amiad Water Systems	<i>Date Issued:</i>	
<i>Program Description:</i>			
<i>Client Ref:</i>	Analysis		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Chemist/Analyst		Team Leader Microbiology
	Bendigo Laboratory Manager		Process Co-ordinator

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5465677		Tank No 8	WATER	18/12/17 12:20
5465678		Tank No 9	WATER	18/12/17 12:40
5465679		Tank No 10	WATER	18/12/17 10:50
5465680		Hydrant	WATER	18/12/17 12:10

Analysis - Analyte	Sample No. Site Code Units	5465677	5465678	5465679	5465680
		BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	2	3
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	2900	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0	0

A blank space indicates no test performed.