



CERTIFICATE OF ANALYSIS

Batch No: 17-02201

Final Report 603643

Laboratory

Page 1 of 2

Address

Page

Scoresby Laboratory Caribbean Business Park.

22 Dalmore Drive.

Scoresby,

VIC 3179

03 9763 1862

03 8756 8000 Phone

Contact:

Fax

Client Manager

PO No: Not Available Date Sampled:

16-Jan-2017

Sampler Name:

Client:

Contact:

Address:

Date Samples Received:

19-Jan-2017

ALS Program Ref:

CFA Date Issued:

Program Description:

Miscellaneous Analyses

Country Fire Authority

PATTERSON LAKES VIC 3197

PO Box 717

Client Ref:

WQMP

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below

indicates methods not covered by NATA accreditation in the performance of this service .

Analysis Method Method Laboratory Laboratory Analysis Colilert (2000) MM514 Scoresby Ps aeruginosa MM528 Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

No water at sample point CFAB01 - Flammable Liquid Tank

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
Analyst			Team Leader Microbiology

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receival and within 24 hours of sampling unless otherwise stated. MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate. MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate. Calculated results are based on raw data.

 Page:
 Page 2 of 2

 Batch No:
 17-02201

 Report Number:
 603643

Client: Country Fire Authority

ALS Program Ref: CFA

Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5042165	CFAB02	South MegalitreTank	WATER	16/01/17 07:20
5042166	CFAB03	North MegalitreTank	WATER	16/01/17 07:30

Analysis - Analyte	Sample No. Site Code Units	5042165 CFAB02	5042166 CFAB03
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.