



## **CERTIFICATE OF ANALYSIS**

**Batch No:** 17-11835

Final Report 612792

Laboratory

Page 1 of 2

Page

Scoresby Laboratory Caribbean Business Park.

Address

22 Dalmore Drive.

Scoresby,

VIC 3179

Phone Fax

03 8756 8000 03 9763 1862

Contact:

Client Manager

01-Mar-2017

PO No: Not Available Date Sampled:

01-Mar-2017

Sampler Name:

Client:

Contact:

Address:

Date Samples Received:

06-Mar-2017

ALS Program Ref:

CFA

Date Issued:

Program Description:

Miscellaneous Analyses

**Country Fire Authority** 

PATTERSON LAKES VIC 3197

PO Box 717

Client Ref: **WQMP** 

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below

indicates methods not covered by NATA accreditation in the performance of this service .

Analysis Method Laboratory Analysis Method Laboratory MB006 MM514 Alg. ScCnt Scoresby Colilert (2000) Scoresby

Ps aeruginosa MM528 Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

## Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name Title Name Title **Team Leader Biology** Analyst **Team Leader Microbiology** 





Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receival and within 24 hours of sampling unless otherwise stated. MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate. MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate. Calculated results are based on raw data.

 Page:
 Page 2 of 2

 Batch No:
 17-11835

 Report Number:
 612792

Client: Country Fire Authority

ALS Program Ref: CFA

Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5118927		GT01-Flammable Liquid tank	WATER	01/03/17 12:40

Analysis - Analyte	Sample No. Site Code Units	5118927
Alg. ScCnt - Algal analyses		NR IND
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	5
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	3

IND Reported independently on separate report

A blank space indicates no test performed.