



CERTIFICATE OF ANALYSIS

Batch No: 17-22116

Final Report 624920

Laboratory

Page

Page 1 of 2

Address

Wangaratta Laboratory 48 Faithfull Street,

Wangaratta,

VIC 3677.

CFA

Phone

03 5722 2688

Address: 1 Ely Street

WANGARATTA VIC 3677

Fax 03 5722 4727

Contact:

Client Manager

PO No: Not Available

Date Sampled:

09-May-2017

Sampler Name:

Client:

Contact:

Date Samples Received:

09-May-2017

ALS Program Ref: CFAWANG

Date Issued:

15-May-2017

Program Description:

Analysis for Amiad Water Systems

Client Ref: WQMP

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below

indicates methods not covered by NATA accreditation in the performance of this service .

Analysis Method Laboratory Method Laboratory Analysis BOD5 WP030 Wangaratta Colilert (2000) MM514 Wangaratta рΗ Wangaratta CM060 B Ps aeruginosa MM528 Wangaratta

SS at 104+/- 2°C WA025 Wangaratta

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Microbiologist		Wangaratta Laboratory
			Manager





Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate. MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

 Page:
 Page 2 of 2

 Batch No:
 17-22116

 Report Number:
 624920

 Client:
 CFA

 ALS Program Ref:
 CFAWANG

ALS Program Ref: CFAWANG

Program Description: Analysis for Amiad Water Systems



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time	
5199678		Underground Tank	WATER	09/05/17 09:55	
5199679		Main Hydrant	WATER	09/05/17 09:50	

Analysis - Analyte	Sample No. Site Code Units	5199678	5199679
pH - pH, units	Units	8.7	7.6
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.